



ADDENDUM NO. 3
April 26, 2021
STATE OF MARYLAND
DEPARTMENT OF GENERAL SERVICES
Ellington E. Churchill, Jr.

PROJECT NO: **DS-430-212-003 (SBR)**
Installation of a new Wunderguard system (SBR)
PROJECT LOCATION: Maryland Department of Health Western Maryland Hospital
1500 Pennsylvania Avenue
Hagerstown, Maryland 21742
Washington County

This Addendum will clarify, add to, delete from, correct and/or change the bid documents for the project referenced above to the extent indicated. This Addendum is hereby made a part of the bid documents on which the contract will be based. By submitting a bid for this solicitation you acknowledge receipt of this addendum. All questions must be in writing and addressed to the Procurement Officer, Imani Felder.

This Addendum includes the following:

Question and Answers:

1. How many doors will receive the new system? The drawing shows 5 but during the walkthrough, only 2 double doors were covered.

1.A. 4 Double doors. (updated requirement from last week)

2. Page 6 of the specifications says an infection control risk assessment will be conducted prior to the start date. Should we bid this project assuming that ICRA Tents will be required?

2.A. I can not answer this question without knowing how the work will be done.

3. Is the Stanley WanderGuard BLUE an approved equal? Attached are data sheets and information on the product.

3.A. Yes, but care should be taken not to rely on Wi-Fi as it does not penetrate most of the walls in this building.

All other terms, conditions and specifications remain unchanged.

END OF ADDENDUM NUMBER: 3



Issued by:

Janice L. Howell

Department of General Services

State of Maryland

301 West Preston Street

Baltimore, Maryland 21201